

# MATERIAL LIST

PcNo	ITEM & DESCRIPTION	REQ'D.	UNIT PRICE	EXTN.
A57	GROUNDING STRAP, 9-1/16" x 1-1/4" x 3/16" FLAT BAR, STEEL - DWG. E-32	1		
P32	3/4" I.P.S. U-BOLT, STEEL - DWG. E-32	1		
P36	2" I.P.S. U-BOLT, STEEL - DWG. E-32	1		
	STREET LIGHTING STANDARD, ANCHOR BASE TYPE, 11" DIA. BOLT CIRCLE	1		
	ANCHOR BOLT, 1" DIA. x 36" - DWG. E-21, TYPE "A"	4		
	1" REG. HEX. NUT, GALV. STL. (2 EA. FURNISHED WITH EA. ANCHOR BOLT) - DWG. E-21	8		
	1" FLAT WASHER, GALV. STL. (2 EA. FURNISHED WITH EA. ANCHOR BOLT) - DWG. E-21	8		
	2" CONDUIT ELL, STD. 90°, GALVANIZED STL. - CPL. TO LENGTH OF 2" GALV. STL. CONDUIT	1		
	2" CONDUIT BUSHING, PLAIN, GALV. STEEL	1		
	2" CONDUIT BUSHING, GROUNDING, BRONZE - O-Z No. GB2008	1		
	CURB BOX, No. 5 SIZE UNLESS NOTED OTHERWISE ON PLANS AND/OR SPECIFICATIONS SEE DWGS. E-9 & E-7 FOR DETAILS	1		
	CONCRETE, SIDEWALK, 5-SACK MIX	1 YD.		
	CONCRETE, LATEX	A.R.		
	CRUSHED ROCK, 3/4" MAXIMUM AGGREGATE	A.R.		

NOTE: THIS PLAN IS NOT A LEGAL ENGINEERING DOCUMENT BUT AN ELECTRONIC DUPLICATE. THE SIGNED CITY OF OAKLAND STANDARD DETAILS FOR PUBLIC WORKS CONSTRUCTION IS AVAILABLE FOR PURCHASE FROM THE CONTRACT ADMINISTRATION DEPARTMENT.

CITY OF OAKLAND

DESIGN AND CONSTRUCTION SERVICES DEPARTMENT



BORED-HOLE FOUNDATION  
30' STANDARD  
W/ LUMINAIRE MAST ARM  
SHEET 3 OF 3

ELECTRICAL SERVICES MANAGER

DATE:   OCT 95    
REV. DATE:   AUG 99  

DRWG.

**E-14**