

**NOTES:**

1. THIS TRENCH DETAIL IS FOR STREET LIGHT AND TRAFFIC SIGNAL ONLY.
2. ALL DIMENSIONS ARE MINIMUM, UNLESS OTHERWISE NOTED
3. DELIVERY TAGS FOR ASPHALT CONCRETE, PORTLAND CEMENT CONCRETE AND BACKFILL MATERIAL SHALL BE SUBMITTED TO THE ENGINEER ON DEMAND. DELIVERY TAGS SHALL INDICATE THE MATERIALS SPECIFIED.
4. ASPHALT CONCRETE PAVING SHALL BE TYPE III D AR4000. ASPHALT CONCRETE PAVING SHALL BE MECHANICALLY COMPACTED WITH A WACKER BS 60Y VIBRATORY RAMMER OR APPROVED EQUAL. 95% RELATIVE COMPACTION SHALL BE REQUIRED. PAVING SURFACE SHALL BE FREE OF IRREGULARITIES.
5. PERMITTEE MAY ELECT TO ELIMINATE SAND BEDDING AND ENCASE CONDUIT IN SLURRY BACKFILL.


H:\Working(Shared)\Projects\Underground\trench drawings\E-92Revision(090205).dwg

CITY OF OAKLAND

PUBLIC WORKS AGENCY ELECTRICAL SERVICES DEPARTMENT



TYPICAL CROSS SECTION  
FOR ROCKWHEELING AND  
TRENCH PAVING DETAIL



*Pall M.A. Chatterjee*  
PWA ELECTRICAL SERVICES MANAGER

DATE : JUNE 2002  
REV. A DATE: SEPTEMBER 2005

DWG.  
E-92